

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-17-10-23-01


- Products:** SPC Floorings, Structure: Deep embossed,
Dimensions: length (1220-1550) mm x width (180-310) mm x thickness (4.0-6.0) mm
- Client:** CHANGZHOU AIPU DECORATIVE MATERIALS CO.,LTD
12 HENGCUI ROAD
HENGLIN TOWN, CHANGZHOU, JIANGSU
CHINA
- Order:** Testing and classification of selected properties according to EN 14041:2008 (CE-labelling)
- Test report:** 278003/92
- Test results:** *The above mentioned SPC floorings can be classified regarding to both properties according to EN 14041:2008 (CE-labelling) as follows:*

Properties	Results	Declaration according to EN 14041:2008
Reaction to fire performance according to EN ISO 9239-1 and EN ISO 11925-2, Classification according to EN 13501-1:2010 - Critical heat flow - Smoke production	11.5 kW / m ² 306 % x min	Reaction to fire class B _n -s1
Sliding behaviour according to EN 13893:2003	μ = 0.38	class DS

Dresden, 23 October 2017



Head of laboratory

Engineer in charge